

EETRL

EVERGREEN ECONOMY TESTING & RESEARCH LABORATORY ISO 9001 (CERTIFIED LABORATORY)

E-5/71, KH. 175, Street No. 12/2, 5th Pusta, Sonia Vihar, Delhi - 110094,
Land Mark behind of Hardan Public School, Mobile: +91-9899705937, 8920039595
E-mail: info.etr12016@gmail.com, info.etr101@gmail.com



TEST REPORT

ISO :9001:2015 Certified

www.etr1.co.in

Sample No./Report No.	EETRL/2025052701/ 520		
Sample Particular	Drinking Water		
Name and Address of customer	M/s P.R.P.S. Public Junior High School Rail Vihar, Sadullabad, Loni, Ghaziabad 201102 Contact Person: Balraj Singh Bhati M.NO. 9350002898		
Date of receipt:	27.05.2025	Start date of Analysis:	27.05.2025
?Date of completion	03.06.2025	Report issue date:	03.06.2025
Condition of sample	OK	Sample Quantity:	1litre
Other Information	NA		
Sampled by Lab representative	Mr. Rajan Kumar		Page No.1 of 1

TEST RESULTS


Sr. No.	Test Parameters	Unit of Measurements	Results	Requirement As per IS.10500:2012 Annexure II	Method Reference
CHEMICAL PARAMETERS					
1.	Colour, Max.	Hazen Unit	1.0	2	IS.3025(Part-4):2015
2.	Odor	-	Agreeable	Agreeable-	IS.3025(Part-5):2015
3.	Taste	-	Agreeable	Agreeable	IS.3025(Part-7 &8):2015
4.	Turbidity (NTU) Max.	NTU	1.0	2.0	IS.3025(Part-10)RA:2017
5.	Total Dissolved Solids (mg/l)	mg/l	95	500-2000	IS.3025(Part-16)RA:2019
6.	pH	-	6.91	6.0-8.5	IS.3025(Part-11)RA:2017
7.	Total Hardness as CaCO ₃ (mg/l) Max.	mg/l	31	200 max./ 600 max.	IS: 3025 (P-21)RA2000
8.	Iron as Fe (mg/l) Max.	mg/l	0.1	0.3 max./No relaxation 0.5	IS: 3025 (P-53)RA:2003
9.	Chloride as Cl (mg/l) Max.	mg/l	18.5	250 max.	IS: 3025 (P-32)RA:2019
10.	Free Residual Chlorine (mg/l) Max.	mg/l	ND	0.20 max.	IS: 3025 (P-26)RA:2019
11.	Fluoride as F (mg/l)	mg/l	0.1	1.0 max./ 1.5 max	IS: 3025 (P-60)RA:2019
12.	Alkalinity	mg/l	5	200 Max	IS 3025 (Part 23)-2019
13.	Nitrate	mg/l	4.2	45 Max.	IS: 3025 (P-34)RA:2019
14.	Sulphate (SO ₄)	mg/l	5.6	200 Max.	IS: 3025 (P-24)RA:2019

Note: Party asks for above tests only (The results related to the item tested.)

End of Report

Ravinder
Head Master
P.R.P.S Public Jr High School
Rail Vihar Loni, Gzb

Yogesh Bhati
Manager
P.R.P.S. Public Jr High School
Rail Vihar, Loni, GZB.



Terms & Conditions: 1. Test reports are valid only for the samples tested in our laboratory. 2. Samples will be destroyed after one month from the date of issue of test certificates unless otherwise specified. 3. Samples tested are Non-Returnable until specified at time of sample submission. 4. This report will not be valid for judicial purpose. 5. Total liability of our laboratory is limited to invoiced amount